# Appendix 1: List of Recommended cables for each Powermount-P720-1505KWh external interface

| No. | Item | Start and end positions | | Type, material | Provider |
|---|---|---|---|---|---|
| 1 | AC power cable | Container AC output port | Buyer's power distribution cabinet | 3*(YJV-0.6/1kV-3*240mm²+2*120 mm²) Copper Wire | Buyer |
| 2 | Aux. power cable （If external wiring is selected） | Aux. external interface | Buyer's power distribution cabinet | YJV-0.6/1kV-3*25 mm² + 2*16mm² Copper Wire | Buyer |
| 3 | Communicate with buyer's monitoring control system | Container external communication interface | buyer's monitoring control system | CAT5E shielded pair | Buyer |
| 4 | Service networking | Container external communication interface | Buyer’s Network | CAT5E shielded pair | Buyer |