Appendix 1: List of Recommended cables for each Powermount-P480-2007KWh external interface

No.	Item	Start and end positions		Type, material	Provider
1	AC power cable	Container AC output port	Buyer's power distribution cabinet	2*(YJV-0.6/1kV-3*240mm²+2*120 mm²) Copper Wire	Buyer
2	Aux. power cable （If external wiring is selected）	Aux. external interface	Buyer's power distribution cabinet	YJV-0.6/1kV-3*25 mm² + 2*16mm² Copper Wire	Buyer
3	Communicate with buyer's monitoring control system	Container external communication interface	buyer's monitoring control system	CAT5E shielded pair	Buyer
4	Service networking	Container external communication interface	Buyer’s Network	CAT5E shielded pair	Buyer